

16 August 1962

MEMORANDUM FOR THE RECORD

FROM : [REDACTED]
SUBJECT: Trip [REDACTED] Re Thin Line Tropo

25X1A9a

25X1A6a

1. On 13 August 1962, Messrs. [REDACTED] and [REDACTED] traveled to [REDACTED] in answer to a request from OC-T for engineering service and/or advice.

25X1A9a

25X1A6a

2. The meeting was held with Mr. [REDACTED] OC-T prior to the meeting with [REDACTED]. In this discussion, Mr. [REDACTED] reiterated his position regarding Communications facilities which he had enclosed in a memorandum to OC-T.

25X1A9a

25X1A9a

3. The members of Communications met with Mr. [REDACTED] the [REDACTED] and his assistant. The plans for the New Building were discussed. Close examination of plans revealed that two 1- $\frac{1}{4}$ " conduit risers went from the basement radio room to the roof. We requested that this conduit be changed to 3" to cover all contingencies. The conduit will be capped on the roof.


25X1A9a

4. We located on the plans a new transmitter building to be erected in the area of the present antenna field. This would enclose the emergency power unit and the 16F transmitter.

25X1A

6. We requested that a 30 amp. service be run from the basement standby power system to areas 206/5 and 235/1 for use with the HW-19 equipment.

~~CONFIDENTIAL~~



-2-

25X1A

7. Discussions were held regarding erection of a tower in the loading dock area at the rear of the building. The [REDACTED] stated that this must be cleared with Mr. Beard, Director of Training. The exact physical location was not definitely decided upon, however, it will be in the northwest corner of the area.

8. Discussions terminated with the understanding that minor modification in the building is to be accomplished locally while antenna erection is to be taken up with the Director of Training.

[REDACTED]

25X1A6a

Distribution:

Original - Routing/File

- 1 - OC-AD
- 1 - OC-T
- 1 - Chrono
- 2 - Monthly Report

~~CONFIDENTIAL~~

GROUP 1
Excluded from automatic
downgrading and
declassification